

Office of the State Forester

Arizona Department of Forestry and Fire Management



FIRE DEPARTMENT ACCESS REQUIREMENTS

No construction shall commence until project plans have been reviewed, approved, and a state permit issued. Construction without a permit shall receive a Red Tag/immediate Stop Work Order. A Stop Work Order will not be lifted until a permit is issued and the contractor pays a re-inspection fee.

State Fire Code requires fire apparatus, to include, emergency vehicles, be provided access to every facility, building, or portion of a building constructed, moved or remodeled, when any portion of the exterior wall of the first story of a building is more than 150ft from a point on the access lane. When access cannot be provided, the State Fire Marshal may require the installation of additional fire protection features.

Fire Access Roads must meet the following minimum requirements listed in the IFC 2018 Fire Code Chapter 5 and Appendix D:

- When the building is completely protected with an approved fire sprinkler system, this distance may be increased to 300 feet with the approval of the Arizona State Fire Marshal.
- Full required access shall be provided prior to any combustible construction on a site.
- Construction site fire access shall be identified by signs posted on the property and visible to the fire
 department. The local fire jurisdiction shall be notified of the location of all fire access roads to a
 construction site.
- Fire access roads shall have an unobstructed width of not less than 20 feet.
- Fire access roads shall have an unobstructed, clear height of 13 feet 6 inches.
- Fire access roads shall be provided with an all-weather driving surface and be constructed to maintain and support the imposed load of fire apparatus. Specifications must be provided with plans.

The responding fire department must be contacted for special fire lane requirements.