



Katie Hobbs  
Governor

## Office of the State Forester

### Arizona Department of Forestry and Fire Management



Thomas A. Torres  
State Forester

## INSPECTION REQUIREMENTS FOR A GENERAL CONSTRUCTION FINAL

The below requirements are based on the 2018 IFC as adopted.

**Note: This permit will be allowed one field inspection only.**

- Approved plans and permit on site
- Appropriate general contractor on site.
- Fire lanes are accessible and marked appropriately.
- Fire lanes are minimum 20 ft. wide.
- Building street addresses correctly sized and readable facing street.
- FDCs facing correctly and identified for building they support.
- Fire hydrants correctly set for fire department access.
- All exit signs illuminated and backup tested.
- Emergency lighting tested.
- Panic hardware tested.
- Fire department lock box (if required) by local jurisdiction.
- General contractor to call for Final when ready.

**This form is used only as a guide. Final approval is contingent upon favorable field inspection.**

Duty ♦ Respect ♦ Integrity