

Office of the State Forester

Arizona Department of Forestry and Fire Management



INSPECTION REQUIREMENTS FOR A GENERAL CONSTRUCTION FINAL

The below requirements are based on the 2012 IFC as adopted.

Note: This permit will be allowed one field inspection only.

- Approved plans and permit on site
- Appropriate general contractor on site.
- Fire lanes are accessible and marked appropriately.
- Fire lanes are minimum 20 ft. wide per 503.2.1.
- Building street addresses correctly sized and readable facing street per 505.
- FDCs facing correctly and identified for building they support.
- Fire hydrants correctly set for fire department access.
- All exit signs illuminated and backup tested.
- Emergency lighting tested.
- Panic hardware tested.
- Fire department lock box (if required) by local jurisdiction.
- General contractor to call for Final when ready.

This form is used only as a guide. Final approval is contingent upon favorable field inspection.

January 2018