



Katie Hobbs
Governor

Office of the State Forester

Arizona Department of Forestry and Fire Management



Thomas A. Torres
State Forester

PLAN REVIEW AND INSPECTION FOR TEMPORARY STRUCTURES AND GENERATORS

Temporary structures and generators are permitted for 180 days.

- Approved plans on site.
- Appropriate contact on site.
- Fire lanes are accessible and marked appropriately.
- Fire lanes are a minimum 20 feet wide
- Temporary structures shall meet NFPA 701 requirements for flame spread documentation needed for plan review.
- All exit signs illuminated.
- Emergency lighting is provided.
- Temporary structures shall be installed per manufacturer's installation requirements.
- Fire extinguishers are in place and properly serviced.
- Temporary generators shall be grounded if power is pulled from them.
- Temporary generators shall be secured from the public.
- Temporary generators' cables shall be secured from all traffic.
- Temporary generators shall be located a minimum 20 feet from combustibles.

This form is used only as a guide. Final approval is contingent upon favorable field inspection.

Duty ♦ Respect ♦ Integrity