



Department of Forestry and Fire Management

Office of the State Fire Marshal

1110 W. Washington Ste. 100

Phoenix, AZ 85007

Main Line (602) 771-1400/Fax (602) 771-1421

PLAN REVIEW AND INSPECTION FOR TEMPORARY STRUCTURES AND GENERATORS

Temporary structures and generators are permitted for 180 days.

- Approved plans on site.
- Appropriate contact on site.
- Fire lanes are accessible and marked appropriately.
- Fire lanes are a minimum 20 feet wide per 503.2.1
- Temporary structures shall meet NFPA 701 requirements for flame spread documentation needed for plan review.
- All exit signs illuminated.
- Emergency lighting is provided.
- Temporary structures shall be installed per manufacturer's installation requirements.
- Fire extinguishers are in place and properly serviced.
- Temporary generators shall be grounded if power is pulled from them.
- Temporary generators shall be secured from the public.
- Temporary generators' cables shall be secured from all traffic.
- Temporary generators shall be located a minimum 20 feet from combustibles.

This form is used only as a guide. Final approval is contingent upon favorable field inspection.

11/2017